

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3240-1591:224

Page 1 of 1

**CATEGORY:** Duct Smoke Detector Housing/Base

**LISTEE:** Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243  
Contact: Leon Newsome (941) 739-4276 FAX (941) 739-4334

**DESIGN:** Model SD-4WPCBJ printed wiring board sensor, replacement photoelectric type with RJ connector for Models TSD-SJ, ESD-SJ, TSD-SJG, TSD-SJCO2 (CSFM Listing No. 3242-1591:223) duct smoke detectors.

Model SD-4WPCBT printed wiring board sensor, replacement photoelectric type with terminal block connector for Models TSD-ST, ESD-ST, TSD-STCO2 (CSFM Listing No. 3242-1591:223) duct smoke detectors.

Refer to the listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, Telaire name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as printed wiring board sensors for use with separately listed duct smoke detectors and separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

06-30-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 30, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**